BONDING THE STARS



acp CO2-Cleaning

Environmental conditions & connections

>> Required compressed air quality

To operate **one nozzle**, the CO₂ cleaning system requires a compressed air supply with application-specific process parameters, e.g. at **6 bar** working pressure, a withdrawal capacity of approx. **300 I/min** (max. 10 bar/ 1000 I/min).

Compressed air quality:

- Oil-free with a pressure dew point of -20 °C
- Ideal quality: [1:3:1:] according to ISO 8573:2010

Transfer point: Ball valve

acp CO2-Cleaning

CO₂ snow blasting is the preferred method of removing contamination at the contacts of battery cells. It is gentle to the surface of the cell contacts and can be carried out quickly and easily before each bonding step.

The system itself consists of a jet nozzle, the JetBox itself and high-pressure CO_2 gas from a conventional gas tank.

>> Required CO2 quality

Carbon dioxide (CO_2) technical grade liquid supply. The CO_2 supply must be suitable for the withdrawal of the liquid phase (e.g., through a dip tube bottle)

Medium conditions for CO₂ liquid supply:

- With a tank supply: 55 bar 60 bar at +10 °C
- If bottles are supplied, they must have the same temperature as the system (no installation outside the building when dispensing)

Transfer point: Ball valve

Extensions (optionally available)

External suction

Centrifugal fan continuously adjustable between 0 and approx. 4 m³/min

- Integrated filter (pocket filter ISO ePM 2.5 60%)
- Width x depth x height = 60 x 35 x 83 cm (incl. wheels)
- Supply and exhaust air sockets with an outside diameter of 100 mm

Compressed Air dehumidifier

- Oil-free with a pressure dew point of -20 °C
- Ideal quality: [1:3:1:] according to ISO 8573:2010



For detailed technical data or general questions about CO₂ cleaning, please contact us by phone on +43 7722-67052-8270 or by e-mail via info@fsbondtec.at.